



Site plan of the proposed development showing three buildings (3164, 3165, 3163) and their boundaries. The plan includes dimensions, area calculations, and a match to existing topography. Building 3164 has an area of 3164 and a boundary of 338.7. Building 3165 has an area of 3165 and a boundary of 337.70. Building 3163 has an area of 3163 and a boundary of 338.00. The plan also shows a match to existing topography and a match to existing wall.



The filling in the areas as defined above and in the Level 1 Report pertaining to the above mentioned project meets the requirements for “structural fill for residential applications” in accordance with AS3798. The fill has been placed, compacted and tested in accordance with AS3798 and the fill meets the requirements for controlled fill in accordance with AS2870 (2011) “Residential Slabs and Footings”.

Martin Williams
Principal Geotechnical Engineer
MSc CGeol CPEng RPEQ RPEV
martinW@ausgeotest.com.au
Tel: 0484 862 371

